

TEXAS COMMISSION ON ENVIRONMENTAL QUALITY
LEAD AND COPPER RULE MONITORING FORM (LCRMF) 20683

COMPLETED BY PWS (OR AGENT)		COMPLETED BY LABORATORY	
PWS Name:	ROH WSC	Laboratory Name:	LCRA Environmental Laboratory Services
PWS ID #:	TX 1990012	LCRQ Laboratory ID #:	1104794219
PWS Address:	P.O. Box 2318 Rockwall TX 75087	Laboratory Address:	3505 Montopolis Drive Austin TX 78744
PWS Contact Name:	Curtis Logan	Laboratory Contact Name:	Jessie Woods
PWS Contact Phone #:	903-477-0501	Laboratory Contact Phone #:	(512) 730-6022
PWS Tap Sample Checklist (✓)		Sample Condition on Receipt	
☒ Samples filled to 1 liter volume	☒ Samples taken from a frequently used inside sink	Samples delivered unpreserved (Y or N):	4 Actual sample temperature (°C): 25.9
☒ Samples collected from cold water tap(s)	☒ Taps were unused for 6 hours prior to collection	Samples collected in 1 liter labeled containers (Y or N):	✓ Corrected sample temperature (°C): 25.9
☒ Sample containers with labels	☒ Samples delivered to lab within 14 days of collection	Samples filled to 1 liter volume (Y or N):	7 Thermometer ID #: 1812

Facility ID (entry point ID# LCRQ#) or Distribution (DS#)	Sample Point ID (entry point ID# LCRQ#) or Distribution (DS#)	Sample Location (address of sample point)	Sample Point Last Used Date (MM/DD/YY)	Sample Point Last Used Time-24 Hr (HH:MM)	Sample Collection Date (MM/DD/YY)	Sample Collection Time-24 Hr (HH:MM)	Regulation Exemption (Y)	Original Sample ID#	Original Collection Date (MM/DD/YY)	Lab Sample ID	Laboratory Preservation Date (MM/DD/YY)	Laboratory Preservation Time-24 Hr (HH:MM)	Sample Rejection Code (if applicable)
DS01	LCR021	881 Collins Rd	10/05/25	1000	10/07/25	1125				Q2516185	10/7/25	17:48	
DS01	LCR022	257 Quail Creek	09/30/25	1300	10/07/25	0955				Q2516185	10/7/25	17:48	
DS01	LCR023	1217 Lovers	10/05/25	1100	10/07/25	0905				Q2516185	10/7/25	17:48	
DS01	LCR024	3085 Bridgemoor	10/05/25	1230	10/06/25	1515				Q2516185	10/7/25	17:48	
DS01	LCR025	210 Hackberry Creek	10/06/25	1130	10/10/25	0933				Q2516185	10/7/25	17:48	
DS01	LCR026	11921 S FM 548	10/06/25	2200	10/09/25	0600				Q2516185	10/7/25	17:48	
DS01	LCR027	3397 W FM 550	10/10/25	2030	10/11/25	1130				Q2516185	10/7/25	17:48	
DS01	LCR028	1971 Jordan Ln	10/07/25	0555	10/07/25	1755				Q2516185	10/7/25	17:48	
DS01	LCR029	717 Kuban Rd	10/05/25	0500	10/07/25	1530				Q2516185	10/7/25	17:48	
DS01	LCR030	112 Watson Woods Trail	10/06/25	2200	10/07/25	0937				Q2516185	10/7/25	17:48	

Sample Collection Acknowledgement

I acknowledge that the information on this form is true and correct and sites selected for sampling follow the approved LCRQ Form 2046-1 and the PWS Monitoring Plan. Violation of this form or tampering with water samples is a crime punishable under state and/or federal law. (Texas Penal Code, Title 8, Chapter 37, Section 37.01)

Name of Authorized PWS Representative (Print):	PWS Representative Signature:	Organization:
Curtis Logan	Curtis Logan	
CHAIN OF CUSTODY (COC)		
Collected By (Signature):	Date/Time:	Received By (Signature):
Curtis Logan	10-11-25 11:00	
Received By (Signature):	Date/Time:	Received By Lab (Signature):

LCRQ 20683 (Rev. 10/2024)

LED LX 8843 2601 4070



02540481
719281

10-11-25 12:45



PWS_1990012_AC_20251006_LCR Analysis Report
LCRA Environmental Laboratory Services
3505 Montopolis Drive
Austin, TX 78744
Phone (512)730-6022
Fax (512)730-6021

October 30, 2025

CURTIS LOGAN
4800 LOFLAND CIRCLE
Rockwall, TX 75032
CLOGAN@RCHWATERSUPPLY.COM

RE: Final Analytical Report Q2540483
Attn: CURTIS LOGAN

Enclosed are the analytical results for sample(s) received by LCRA Environmental Laboratory Services. Results reported herein conform to the most current NELAP standards, where applicable, unless otherwise narrated in the body of the report. This final report provides results related only to the sample(s) as received for the above referenced work order.

Thank you for selecting ELS for your analytical needs. If you have any questions regarding this report, please contact us at (512) 730-6022 or environmental.lab@lcra.org. We look forward to assisting you again.

Authorized for release by:

Rhys Woodruff
Quality Assurance Specialist
Rhys.woodruff@lcra.org



Enclosures:
CC:ROBIN MAYALL

Workorder: Q2540483
Workorder Description: TX1990012_LCR_10_15_2025
Client: RCH WSC
Profile: LEAD AND COPPER PROGRAM
Sampled By: RESIDENT

Report To: CURTIS LOGAN
4800 LOFLAND CIRCLE
Rockwall, TX 75032

Sample Summary

Lab ID	Sample ID	Matrix	Method	Date Collected	Date Received	Analytes Reported
Q2540483001	LCR021	DW	E200.8, ICP-MS Lead/Copper	10/07/2025 11:25	10/14/2025 12:05	2
Q2540483002	LCR022	DW	E200.8, ICP-MS Lead/Copper	10/07/2025 09:55	10/14/2025 12:05	2
Q2540483003	LCR023	DW	E200.8, ICP-MS Lead/Copper	10/07/2025 09:05	10/14/2025 12:05	2
Q2540483004	LCR024	DW	E200.8, ICP-MS Lead/Copper	10/06/2025 15:15	10/14/2025 12:05	2
Q2540483005	LCR025	DW	E200.8, ICP-MS Lead/Copper	10/10/2025 09:33	10/14/2025 12:05	2
Q2540483006	LCR026	DW	E200.8, ICP-MS Lead/Copper	10/09/2025 06:00	10/14/2025 12:05	2
Q2540483007	LCR027	DW	E200.8, ICP-MS Lead/Copper	10/11/2025 11:30	10/14/2025 12:05	2
Q2540483008	LCR028	DW	E200.8, ICP-MS Lead/Copper	10/07/2025 17:55	10/14/2025 12:05	2
Q2540483009	LCR029	DW	E200.8, ICP-MS Lead/Copper	10/07/2025 15:30	10/14/2025 12:05	2
Q2540483010	LCR030	DW	E200.8, ICP-MS Lead/Copper	10/07/2025 09:37	10/14/2025 12:05	2

Report Definitions

MRL - Minimum Reporting Limit
LOD - Limit of Detection
ML - Maximum Limit - Client Specified
MCL - Maximum Contaminant Level
LOQ - Limit of Quantitation - Client Specified
DF - Dilution Factor
(S) - Surrogate Spike
MDL - Method Detection Limit
RPD - Relative Percent Difference

Qualifier Definitions

J - Analyte detected below quantitation limit
R - RPD outside duplicate precision limit
S - Spike recovery outside limit
B - Analyte detected in method blank
N - Not Accredited
M - Analyte Detected Above Maximum Contaminant Level
SL - Spike Recovery Low
SH - Spike Recovery High
H - Analyzed Past Hold Time
CR - Confirmed Result
CH - Result confirmed by historical data



PWS_1990012_AC_20251006_LCR Analysis Report
LCRA Environmental Laboratory Services
3505 Montopolis Drive
Austin, TX 78744
Phone (512)730-6022
Fax (512)730-6021

Workorder Summary

Analytical Results

Client ID: TX1990012	Date Collected: 10/07/2025 11:25	Matrix: Drinking Water
Lab ID: Q2540483001	Date Received: 10/14/2025 12:05	Sample Type: SAMPLE
Sample ID: LCR021	Location: 863 CULLINS RD	
Project ID: LEAD AND COPPER PROGRAM	Facility: DS01	
	Sample Point: LCR021	

INORGANICS (E200.8, ICP-MS Prep/E200.8, ICP-MS Lead/Copper)

Parameter	Results	Units	MRL	LOD	MCL	DF	Prepared	By	Analyzed	By	Qualifier
Copper Total	0.777	mg/L	0.00200	0.00200	1.3	2	10/16/2025 09:47	ML	10/29/2025 19:37	MMO	

INORGANICS (E200.8, ICP-MS Prep/E200.8, ICP-MS Lead/Copper)

Parameter	Results	Units	MRL	LOD	MCL	DF	Prepared	By	Analyzed	By	Qualifier
Lead Total	<0.0010	mg/L	0.0010	0.0010	0.015	1	10/16/2025 09:47	ML	10/20/2025 20:50	MMO	

Analytical Results

Client ID: TX1990012	Date Collected: 10/07/2025 09:55	Matrix: Drinking Water
Lab ID: Q2540483002	Date Received: 10/14/2025 12:05	Sample Type: SAMPLE
Sample ID: LCR022	Location: 252 QUAIL CREEK	
Project ID: LEAD AND COPPER PROGRAM	Facility: DS01	
	Sample Point: LCR022	

INORGANICS (E200.8, ICP-MS Prep/E200.8, ICP-MS Lead/Copper)

Parameter	Results	Units	MRL	LOD	MCL	DF	Prepared	By	Analyzed	By	Qualifier
Copper Total	0.0440	mg/L	0.00100	0.00100	1.3	1	10/16/2025 09:47	ML	10/20/2025 20:51	MMO	
Lead Total	<0.0010	mg/L	0.0010	0.0010	0.015	1	10/16/2025 09:47	ML	10/20/2025 20:51	MMO	



PWS_1990012_AC_20251006_LCR Analysis Report
LCRA Environmental Laboratory Services
3505 Montopolis Drive
Austin, TX 78744
Phone (512)730-6022
Fax (512)730-6021

Analytical Results

Client ID: TX1990012	Date Collected: 10/07/2025 09:05	Matrix: Drinking Water
Lab ID: Q2540483003	Date Received: 10/14/2025 12:05	Sample Type: SAMPLE
Sample ID: LCR023	Location: 1217 LIVORNO	
Project ID: LEAD AND COPPER PROGRAM	Facility: DS01	
	Sample Point: LCR023	

INORGANICS (E200.8, ICP-MS Prep/E200.8, ICP-MS Lead/Copper)

Parameter	Results	Units	MRL	LOD	MCL	DF	Prepared	By	Analyzed	By	Qualifier
Copper Total	0.0400	mg/L	0.00100	0.00100	1.3	1	10/16/2025 09:47	ML	10/20/2025 20:52	MMO	
Lead Total	<0.0010	mg/L	0.0010	0.0010	0.015	1	10/16/2025 09:47	ML	10/20/2025 20:52	MMO	

Analytical Results

Client ID: TX1990012	Date Collected: 10/06/2025 15:15	Matrix: Drinking Water
Lab ID: Q2540483004	Date Received: 10/14/2025 12:05	Sample Type: SAMPLE
Sample ID: LCR024	Location: 3085 BRIDGECREEK	
Project ID: LEAD AND COPPER PROGRAM	Facility: DS01	
	Sample Point: LCR024	

INORGANICS (E200.8, ICP-MS Prep/E200.8, ICP-MS Lead/Copper)

Parameter	Results	Units	MRL	LOD	MCL	DF	Prepared	By	Analyzed	By	Qualifier
Copper Total	0.0385	mg/L	0.00100	0.00100	1.3	1	10/16/2025 09:47	ML	10/20/2025 20:54	MMO	
Lead Total	<0.0010	mg/L	0.0010	0.0010	0.015	1	10/16/2025 09:47	ML	10/20/2025 20:54	MMO	



PWS_1990012_AC_20251006_LCR Analysis Report
LCRA Environmental Laboratory Services
3505 Montopolis Drive
Austin, TX 78744
Phone (512)730-6022
Fax (512)730-6021

Analytical Results

Client ID:	TX1990012	Date Collected:	10/10/2025 09:33	Matrix:	Drinking Water
Lab ID:	Q2540483005	Date Received:	10/14/2025 12:05	Sample Type:	SAMPLE
Sample ID:	LCR025	Location:	210 HACKBERRY CREEK		
Project ID:	LEAD AND COPPER PROGRAM	Facility:	DS01		
		Sample Point:	LCR025		

INORGANICS (E200.8, ICP-MS Prep/E200.8, ICP-MS Lead/Copper)

Parameter	Results	Units	MRL	LOD	MCL	DF	Prepared	By	Analyzed	By	Qualifier
Copper Total	0.0214	mg/L	0.00100	0.00100	1.3	1	10/16/2025 09:47	ML	10/20/2025 20:55	MMO	
Lead Total	<0.0010	mg/L	0.0010	0.0010	0.015	1	10/16/2025 09:47	ML	10/20/2025 20:55	MMO	



PWS_1990012_AC_20251006_LCR Analysis Report
LCRA Environmental Laboratory Services
3505 Montopolis Drive
Austin, TX 78744
Phone (512)730-6022
Fax (512)730-6021

Analytical Results

Client ID:	TX1990012	Date Collected:	10/09/2025 06:00	Matrix:	Drinking Water
Lab ID:	Q2540483006	Date Received:	10/14/2025 12:05	Sample Type:	SAMPLE
Sample ID:	LCR026	Location:	11921 S FM 548		
Project ID:	LEAD AND COPPER PROGRAM	Facility:	DS01		
		Sample Point:	LCR026		

INORGANICS (E200.8, ICP-MS Prep/E200.8, ICP-MS Lead/Copper)

Parameter	Results	Units	MRL	LOD	MCL	DF	Prepared	By	Analyzed	By	Qualifier
Copper Total	0.0434	mg/L	0.00100	0.00100	1.3	1	10/16/2025 09:47	ML	10/20/2025 20:57	MMO	
Lead Total	<0.0010	mg/L	0.0010	0.0010	0.015	1	10/16/2025 09:47	ML	10/20/2025 20:57	MMO	



PWS_1990012_AC_20251006_LCR Analysis Report
LCRA Environmental Laboratory Services
3505 Montopolis Drive
Austin, TX 78744
Phone (512)730-6022
Fax (512)730-6021

Analytical Results

Client ID: TX1990012	Date Collected: 10/11/2025 11:30	Matrix: Drinking Water
Lab ID: Q2540483007	Date Received: 10/14/2025 12:05	Sample Type: SAMPLE
Sample ID: LCR027	Location: 3397 W FM 550	
Project ID: LEAD AND COPPER PROGRAM	Facility: DS01	
	Sample Point: LCR027	

INORGANICS (E200.8, ICP-MS Prep/E200.8, ICP-MS Lead/Copper)

Parameter	Results	Units	MRL	LOD	MCL	DF	Prepared	By	Analyzed	By	Qualifier
Copper Total	0.0715	mg/L	0.00100	0.00100	1.3	1	10/16/2025 09:47	ML	10/20/2025 20:58	MMO	
Lead Total	<0.0010	mg/L	0.0010	0.0010	0.015	1	10/16/2025 09:47	ML	10/20/2025 20:58	MMO	



PWS_1990012_AC_20251006_LCR Analysis Report
LCRA Environmental Laboratory Services
3505 Montopolis Drive
Austin, TX 78744
Phone (512)730-6022
Fax (512)730-6021

Analytical Results

Client ID:	TX1990012	Date Collected:	10/07/2025 17:55	Matrix:	Drinking Water
Lab ID:	Q2540483008	Date Received:	10/14/2025 12:05	Sample Type:	SAMPLE
Sample ID:	LCR028	Location:	1971 JORDAN LN		
Project ID:	LEAD AND COPPER PROGRAM	Facility:	DS01		
		Sample Point:	LCR028		

INORGANICS (E200.8, ICP-MS Prep/E200.8, ICP-MS Lead/Copper)											
Parameter	Results	Units	MRL	LOD	MCL	DF	Prepared	By	Analyzed	By	Qualifier
Copper Total	0.398	mg/L	0.00100	0.00100	1.3	1	10/16/2025 09:47	ML	10/20/2025 20:59	MMO	
Lead Total	<0.0010	mg/L	0.0010	0.0010	0.015	1	10/16/2025 09:47	ML	10/20/2025 20:59	MMO	



PWS_1990012_AC_20251006_LCR Analysis Report
LCRA Environmental Laboratory Services
3505 Montopolis Drive
Austin, TX 78744
Phone (512)730-6022
Fax (512)730-6021

Analytical Results

Client ID:	TX1990012	Date Collected:	10/07/2025 15:30	Matrix:	Drinking Water
Lab ID:	Q2540483009	Date Received:	10/14/2025 12:05	Sample Type:	SAMPLE
Sample ID:	LCR029	Location:	717 KUBAN RD		
Project ID:	LEAD AND COPPER PROGRAM	Facility:	DS01		
		Sample Point:	LCR029		

INORGANICS (E200.8, ICP-MS Prep/E200.8, ICP-MS Lead/Copper)											
Parameter	Results	Units	MRL	LOD	MCL	DF	Prepared	By	Analyzed	By	Qualifier
Copper Total	0.0360	mg/L	0.00100	0.00100	1.3	1	10/16/2025 09:47	ML	10/20/2025 21:01	MMO	
Lead Total	<0.0010	mg/L	0.0010	0.0010	0.015	1	10/16/2025 09:47	ML	10/20/2025 21:01	MMO	

Analytical Results

Client ID: TX1990012	Date Collected: 10/07/2025 09:37	Matrix: Drinking Water
Lab ID: Q2540483010	Date Received: 10/14/2025 12:05	Sample Type: SAMPLE
Sample ID: LCR030	Location: 112 WATSON WOODS TRAIL	
Project ID: LEAD AND COPPER PROGRAM	Facility: DS01	
	Sample Point: LCR030	

INORGANICS (E200.8, ICP-MS Prep/E200.8, ICP-MS Lead/Copper)

Parameter	Results	Units	MRL	LOD	MCL	DF	Prepared	By	Analyzed	By	Qual
Copper Total	0.0351	mg/L	0.00100	0.00100	1.3	1	10/16/2025 09:47	ML	10/20/2025 21:02	MMO	
Lead Total	<0.0010	mg/L	0.0010	0.0010	0.015	1	10/16/2025 09:47	ML	10/20/2025 21:02	MMO	

Quality Control Results

QC Batch: MET/11354 **Analysis Method:** E200.8, ICP-MS Lead/Copper
Preparation Method: E200.8, ICP-MS Lead/Copper
Associated Lab IDs: Q2540483001, Q2540483002, Q2540483003, Q2540483004, Q2540483005, Q2540483006, Q2540483007,
Q2540483008, Q2540483009, Q2540483010

Method Reporting Limit Check (2319325)

Parameter	Units	Spiked Amount	Spike Result	Spike Recovery%	Control Limits %	Qualifier
Copper Total	mg/L	0.001	0.0013	129.0	50 - 150	
Lead Total	mg/L	0.001	0.001	104.0	50 - 150	

Quality Control Results

QC Batch: MET/11354 Analysis Method: E200.8, ICP-MS Lead/Copper
Preparation Method: E200.8, ICP-MS Prep
Associated Lab IDs: Q2540483001, Q2540483002, Q2540483003, Q2540483004, Q2540483005, Q2540483006, Q2540483007,
Q2540483008, Q2540483009, Q2540483010

Laboratory Fortified Matrix (2317780); Lab Fortified Matrix Duplicate (2317781); Original: Q2540483001

Parameter	Units	Spiked Amount	Spike Result	%Spike Recovery	Control Limits %	Duplicate Result	%Duplicate Recovery	RPD	RPD Limit	Qualifier
Copper Total	mg/L	0.05	0.831	106.0	70 - 130	0.844	133.0	1.55	20	
Lead Total	mg/L	0.05	0.0482	96.0	70 - 130	0.0508	101.0	5.25	20	

Laboratory Reagent Blank(2317698)

Parameter	Units	Results	MRL	LOD	Qualifier
Copper Total	mg/L	<0.00100	0.001	0.001	
Lead Total	mg/L	<0.0010	0.001	0.001	

Laboratory Fortified Blank (2317699); Lab Fortified Blank Duplicate (2317700)

Parameter	Units	Spiked Amount	Spike Result	%Spike Recovery	Control Limits %	Duplicate Result	%Duplicate Recovery	RPD	RPD Limit	Qualifier
Copper Total	mg/L	0.05	0.0506	101.0	85 - 115	0.0498	99.7	1.59	20	
Lead Total	mg/L	0.05	0.0493	98.6	85 - 115	0.0491	98.2	0.407	20	



PWS_1990012_AC_20251006_LCR Analysis Report
LCRA Environmental Laboratory Services
3505 Montopolis Drive
Austin, TX 78744
Phone (512)730-6022
Fax (512)730-6021

Quality Control Results

QC Batch: MET/11368
Preparation Method: E200.8, ICP-MS Lead/Copper
Associated Lab IDs: Q2540483001

Analysis Method: E200.8, ICP-MS Lead/Copper

Method Reporting Limit Check (2323481)

Parameter	Units	Spiked Amount	Spike Result	Spike Recovery%	Control Limits %	Qualifier
Copper Total	mg/L	0.001	0.0011	107.0	50 - 150	

QC Cross Reference

Lab ID	Sample ID	Prep Batch	Prep Method
<i>MET/11354 - E200.8, ICP-MS Lead/Copper</i>			
Q2540483001	LCR021	MEP/14789	E200.8, ICP-MS Prep
Q2540483002	LCR022	MEP/14789	E200.8, ICP-MS Prep
Q2540483003	LCR023	MEP/14789	E200.8, ICP-MS Prep
Q2540483004	LCR024	MEP/14789	E200.8, ICP-MS Prep
Q2540483005	LCR025	MEP/14789	E200.8, ICP-MS Prep
Q2540483006	LCR026	MEP/14789	E200.8, ICP-MS Prep
Q2540483007	LCR027	MEP/14789	E200.8, ICP-MS Prep
Q2540483008	LCR028	MEP/14789	E200.8, ICP-MS Prep
Q2540483009	LCR029	MEP/14789	E200.8, ICP-MS Prep
Q2540483010	LCR030	MEP/14789	E200.8, ICP-MS Prep
<i>MET/11368 - E200.8, ICP-MS Lead/Copper</i>			
Q2540483001	LCR021	MEP/14789	E200.8, ICP-MS Prep

End of Report

TEXAS COMMISSION ON ENVIRONMENTAL QUALITY
LEAD AND COPPER RULE MONITORING FORM (LCRMF) 20683

COMPLETED BY PWS (OR AGENT)		COMPLETED BY LABORATORY	
PWS Name:	RCH WSC	Laboratory Name:	LCRA Environmental Laboratory Services
PWS ID #:	TX 1990012	TCEQ Laboratory ID #:	T104704218
PWS Address:	P.O. Box 2318 Rockwall TX 75087	Laboratory Address:	3505 Montopolis Drive, Austin, TX 78744
PWS Contact Name:	Curtis Logan	Laboratory Contact Name:	Jasir Woods
PWS Contact Phone #:	903-477-0501	Laboratory Contact Phone #:	(877) 362-5272
PWS Tap Sample Checklist (✓)		Sample Condition on Receipt	
☒ Samples filled to 1 liter volume	☒ Samples taken from a frequently used inside tap	Samples delivered unpreserved (Y or N)	Y
☒ Samples collected from cold water tap(s)	☒ Taps were unused for 6 hours prior to collection	Samples collected in 1 liter labeled containers (Y or N)	Y
☒ Sample containers with labels	☒ Samples delivered to lab within 14 days of collection	Samples filled to 1 liter volume (Y or N)	Y
		Actual sample temperature (°C):	25.5
		Collected sample temperature (°C):	25.4
		Thermometer ID #:	1210

Facility ID entry point (FACID001) or distribution (DS01)	Sample Point ID entry point (SPID001) or distribution (DS01)	Sample Location (address of sample point)	Sample Faucet Last Used Date (MM/DD/YYYY)	Sample Faucet Last Used Time-24 Hr (HH:MM)	Sample Collected Date (MM/DD/YYYY)	Sample Collection Time-24 Hr (HH:MM)	Residuals (Y or N)	Original Sample ID#	Original Collection Date (MM/DD/YYYY)	Lab Sample ID	Laboratory Preservation Date (MM/DD/YYYY)	Laboratory Preservation Time- 24 Hr (HH:MM)	Sample Rejection Code (if applicable)
DS01	LCR003	909 Cullins Rd.	10/06/25	0700	10/07/25	0648				0240423 012.14.25		17:45	
DS01	LCR012	561 Pullen Rd.	10/06/25	1900	10/06/25	1027				-002			
DS01	LCR013	2140 Chisholm Trl.	10/06/25	1915	10/07/25	0745				-003			
DS01	LCR014	635 Dove Landing	10/06/25	1800	10/07/25	0540				-004			
DS01	LCR015	1400 Wheelers Way	10/04/25	1200	10/06/25	1209				-001			
DS01	LCR016	227 Pheasant Hill	10/05/25	1000	10/07/25	0900				-006			
DS01	LCR017	200 Horseshoe Bend	10/06/25	1530	10/07/25	0630				-007			
DS01	LCR018	1406 S. Hwy 205	10/06/25	0325	10/06/25	1340				-002			
DS01	LCR019	639 Wilderness Trail	10/06/25	2300	10/07/25	0500				-009			
DS01	LCR020	1411 Hwy 205	10/06/25	2000	10/07/25	0715				-010			

Sample Collection Acknowledgement		Laboratory Comments	
I acknowledge that the information on this form is true and correct and that selected for sampling follow the approved TCEQ Form 20467 and the PWS Monitoring Plan. Fabrication of this form or tampering with water samples is a crime punishable under state and/or federal law. (Texas Penal Code, Title 8, Chapter 37, Section 37.10)		 0240423 012.14.25	
Name of Authorized PWS Representative (Print)	PWS Representative Signature	Organization	
Curtis Logan	Curtis Logan		
CHAIN OF CUSTODY (COC)			
Subscribed By (Signature)	Date/Time	Subscribed By Courier (Signature)	Date/Time
Curtis Logan	10-10-25 11:00		
Received By Courier (Signature)	Date/Time	Received By Lab (Signature)	Date/Time
			10.14.25 12:45

TCEQ-20683 (Rev. 11/2023)

FED EX 0843 2601 8600

Page 1 of 1

TEXAS COMMISSION ON ENVIRONMENTAL QUALITY
LEAD AND COPPER RULE MONITORING FORM (LCRMF) 20683

COMPLETED BY PWS (OR AGENT)		COMPLETED BY LABORATORY	
PWS Name:	RCH WSC	Laboratory Name:	LCRA Environmental Laboratory Services
PWS ID #:	19 1990012	TEQ Laboratory ID #:	T104704218
PWS Address:	P.O. Box 2318 Rockwall TX 75087	Laboratory Address:	3505 Montopolis Drive, Austin, TX 78744
PWS Contact Name:	Curtis Logan	Laboratory Contact Name:	Janon Woods
PWS Contact Phone #:	903-477-0501	Laboratory Contact Phone #:	(877) 362-5272
PWS Tap Sample Checklist (✓)		Sample Condition on Receipt	
☒ Samples filled to 1 Liter volume	☒ Samples taken from a frequently used inside sink	Samples delivered unpreserved (Y or N)	Y
☒ Samples collected from cold water tap(s)	☒ Sinks were unused for 6 hours prior to collection	Samples collected in 1 liter labeled containers (Y or N)	Y
☒ Sample containers with labels	☒ Samples delivered to lab within 14 days of collection	Samples filled to 1 Liter volume (Y or N)	Y
		Actual sample temperature (°C):	23.3
		Controlled sample temperature (°C):	23.2
		Thermometer ID #:	1818

Facility ID entry point (PWS/DOH) or Distribution (DWSL)	Sample Point ID entry point (LCR) or Distribution (LCR/DWS)	Sample Location (address of sample point)	Sample Faucet Last Used Date (MM/DD/YY)	Sample Faucet Last Used Time-24 Hr (HH:MM)	Sample Collected Date (MM/DD/YY)	Sample Collection Time-24 Hr (HH:MM)	Replicate Number (Y)	Original Sample ID#	Original Collection Date (MM/DD/YY)	Lab Sample ID	Laboratory Preservation Date (MM/DD/YY)	Laboratory Preservation Time- 24 Hr (HH:MM)	Sample Rejection Code (if applicable)
DS01	LCR031	904 Hamilton Ct	10/06/25	0900	10/07/25	1445				-011	10/14/25	17:17	
DS01	LCR032	1032 Kingsbridge	10/07/25	2000	10/08/25	0715				-012			
DS01	LCR033	1497 S. Sp 205	10/06/25	2200	10/07/25	1415				013			
DS01	LCR034	312 Bishopal	10/07/25	2345	10/08/25	0645				014			
DS01	LCR035	410 E. FM 550	10/08/25	2200	10/09/25	1000				-015			
DS01	LCR036	1540 Hipasso Way	10/05/25	0900	10/06/25	1457				-016			
DS01	LCR037	1332 Somerset Ln	10/08/25	1951	10/09/25	0641				017			
DS01	LCR038	484 Savanna Hill	10/06/25	2200	10/07/25	1340				-018			
DS01	LCR039	108 Rose Marie Ln.	10/06/25	1100	10/07/25	1200				019			
DS01	LCR040	403 Travis Ln.	10/07/25	1900	10/08/25	0723				-020			

Sample Collection Acknowledgement		Laboratory Comments	
I acknowledge that the information on this form is true and correct and sites selected for sampling follow the approved TCEQ Form 20467 and the PWS Monitoring Plan. Fabrication of this form or tampering with water samples is a crime punishable under State and/or Federal law. (Texas Penal Code, Title 8, Chapter 37, Section 37.10)			
Name of Authorized PWS Representative (Print)	PWS Representative Signature	Organization	Date
Curtis Logan	Curtis Logan		
CHAIN OF CUSTODY (COC)			
Relinquished By (Signature)	Date/Time	Relinquished By Courier (Signature)	Date/Time
Curtis Logan	10-10-25 8:00		
Received By Courier (Signature)	Date/Time	Received By Lab (Signature)	Date/Time
		JAC	10/14/25 12:05

TCEQ 20683 (Rev. 11/2021)

GED EX 4843 2681 8796



PWS_1990012_AC_20251006_LCR Analysis Report
LCRA Environmental Laboratory Services
3505 Montopolis Drive
Austin, TX 78744
Phone (512)730-6022
Fax (512)730-6021

October 30, 2025

CURTIS LOGAN
4800 LOFLAND CIRCLE
Rockwall, TX 75032
CLOGAN@RCHWATERSUPPLY.COM

RE: Final Analytical Report Q2540423
Attn: CURTIS LOGAN

Enclosed are the analytical results for sample(s) received by LCRA Environmental Laboratory Services. Results reported herein conform to the most current NELAP standards, where applicable, unless otherwise narrated in the body of the report. This final report provides results related only to the sample(s) as received for the above referenced work order.

Thank you for selecting ELS for your analytical needs. If you have any questions regarding this report, please contact us at (512) 730-6022 or environmental.lab@lcra.org. We look forward to assisting you again.

Authorized for release by:

Rhys Woodruff
Quality Assurance Specialist
Rhys.woodruff@lcra.org



Enclosures:
CC:ROBIN MAYALL



PWS_1990012_AC_20251006_LCR Analysis Report
LCRA Environmental Laboratory Services
3505 Montopolis Drive
Austin, TX 78744
Phone (512)730-6022
Fax (512)730-6021

Workorder: Q2540423
Workorder Description: TX1990012_LCR_10_14_2025
Client: RCH WSC
Profile: LEAD AND COPPER PROGRAM
Sampled By: RESIDENT

Report To: CURTIS LOGAN
4800 LOFLAND CIRCLE
Rockwall, TX 75032

Sample Summary

Lab ID	Sample ID	Matrix	Method	Date Collected	Date Received	Analytes Reported
Q2540423001	LCR003	DW	E200.8, ICP-MS Lead/Copper	10/07/2025 06:48	10/14/2025 12:05	2
Q2540423002	LCR012	DW	E200.8, ICP-MS Lead/Copper	10/06/2025 10:27	10/14/2025 12:05	2
Q2540423003	LCR013	DW	E200.8, ICP-MS Lead/Copper	10/07/2025 07:45	10/14/2025 12:05	2
Q2540423004	LCR014	DW	E200.8, ICP-MS Lead/Copper	10/07/2025 05:40	10/14/2025 12:05	2
Q2540423005	LCR015	DW	E200.8, ICP-MS Lead/Copper	10/06/2025 12:09	10/14/2025 12:05	2
Q2540423006	LCR016	DW	E200.8, ICP-MS Lead/Copper	10/07/2025 09:00	10/14/2025 12:05	2
Q2540423007	LCR017	DW	E200.8, ICP-MS Lead/Copper	10/07/2025 05:30	10/14/2025 12:05	2
Q2540423008	LCR018	DW	E200.8, ICP-MS Lead/Copper	10/06/2025 13:40	10/14/2025 12:05	2
Q2540423009	LCR019	DW	E200.8, ICP-MS Lead/Copper	10/07/2025 05:00	10/14/2025 12:05	2
Q2540423010	LCR020	DW	E200.8, ICP-MS Lead/Copper	10/07/2025 07:15	10/14/2025 12:05	2
Q2540423011	LCR031	DW	E200.8, ICP-MS Lead/Copper	10/07/2025 14:45	10/14/2025 12:05	2
Q2540423012	LCR032	DW	E200.8, ICP-MS Lead/Copper	10/08/2025 07:15	10/14/2025 12:05	2
Q2540423013	LCR033	DW	E200.8, ICP-MS Lead/Copper	10/07/2025 14:15	10/14/2025 12:05	2
Q2540423014	LCR034	DW	E200.8, ICP-MS Lead/Copper	10/08/2025 06:45	10/14/2025 12:05	2
Q2540423015	LCR035	DW	E200.8, ICP-MS Lead/Copper	10/09/2025 10:00	10/14/2025 12:05	2
Q2540423016	LCR036	DW	E200.8, ICP-MS Lead/Copper	10/08/2025 14:57	10/14/2025 12:05	2
Q2540423017	LCR037	DW	E200.8, ICP-MS Lead/Copper	10/09/2025 06:41	10/14/2025 12:05	2
Q2540423018	LCR038	DW	E200.8, ICP-MS Lead/Copper	10/07/2025 13:40	10/14/2025 12:05	2
Q2540423019	LCR039	DW	E200.8, ICP-MS Lead/Copper	10/07/2025 12:00	10/14/2025 12:05	2
Q2540423020	LCR040	DW	E200.8, ICP-MS Lead/Copper	10/08/2025 07:23	10/14/2025 12:05	2

Report Definitions

MRL - Minimum Reporting Limit
LOD - Limit of Detection
ML - Maximum Limit - Client Specified
MCL - Maximum Contaminant Level
LOQ - Limit of Quantitation - Client Specified
DF - Dilution Factor
(S) - Surrogate Spike
MDL - Method Detection Limit
RPD - Relative Percent Difference

Qualifier Definitions



PWS_1990012_AC_20251006_LCR Analysis Report
LCRA Environmental Laboratory Services
3505 Montopolis Drive
Austin, TX 78744
Phone (512)730-6022
Fax (512)730-6021

J - Analyte detected below quantitation limit
R - RPD outside duplicate precision limit
S - Spike recovery outside limit
B - Analyte detected in method blank
N - Not Accredited
M - Analyte Detected Above Maximum Contaminant Level
SL - Spike Recovery Low
SH - Spike Recovery High
H - Analyzed Past Hold Time
CR - Confirmed Result
CH - Result confirmed by historical data



PWS_1990012_AC_20251006_LCR Analysis Report
LCRA Environmental Laboratory Services
3505 Montopolis Drive
Austin, TX 78744
Phone (512)730-6022
Fax (512)730-6021

Workorder Summary

Analytical Results

Client ID: TX1990012	Date Collected: 10/07/2025 06:48	Matrix: Drinking Water
Lab ID: Q2540423001	Date Received: 10/14/2025 12:05	Sample Type: SAMPLE
Sample ID: LCR003	Location: 909 CULLINS RD	
Project ID: LEAD AND COPPER PROGRAM	Facility: DS01	
	Sample Point: LCR003	

INORGANICS (E200.8, ICP-MS Prep/E200.8, ICP-MS Lead/Copper)

Parameter	Results	Units	MRL	LOD	MCL	DF	Prepared	By	Analyzed	By	Qualifier
Copper Total	0.0773	mg/L	0.00100	0.00100	1.3	1	10/16/2025 06:41	ML	10/20/2025 20:07	MMO	
Lead Total	<0.0010	mg/L	0.0010	0.0010	0.015	1	10/16/2025 06:41	ML	10/20/2025 20:07	MMO	



PWS_1990012_AC_20251006_LCR Analysis Report
LCRA Environmental Laboratory Services
3505 Montopolis Drive
Austin, TX 78744
Phone (512)730-6022
Fax (512)730-6021

Analytical Results

Client ID: TX1990012	Date Collected: 10/06/2025 10:27	Matrix: Drinking Water
Lab ID: Q2540423002	Date Received: 10/14/2025 12:05	Sample Type: SAMPLE
Sample ID: LCR012	Location: 561 PULLEN RD	
Project ID: LEAD AND COPPER PROGRAM	Facility: DS01	
	Sample Point: LCR012	

INORGANICS (E200.8, ICP-MS Prep/E200.8, ICP-MS Lead/Copper)

Parameter	Results	Units	MRL	LOD	MCL	DF	Prepared	By	Analyzed	By	Qualifier
Copper Total	0.113	mg/L	0.00100	0.00100	1.3	1	10/16/2025 06:41	ML	10/20/2025 20:08	MMO	
Lead Total	<0.0010	mg/L	0.0010	0.0010	0.015	1	10/16/2025 06:41	ML	10/20/2025 20:08	MMO	



PWS_1990012_AC_20251006_LCR Analysis Report
LCRA Environmental Laboratory Services
3505 Montopolis Drive
Austin, TX 78744
Phone (512)730-6022
Fax (512)730-6021

Analytical Results

Client ID: TX1990012	Date Collected: 10/07/2025 07:45	Matrix: Drinking Water
Lab ID: Q2540423003	Date Received: 10/14/2025 12:05	Sample Type: SAMPLE
Sample ID: LCR013	Location: 2140 CHISOLM TRL	
Project ID: LEAD AND COPPER PROGRAM	Facility: DS01	
	Sample Point: LCR013	

INORGANICS (E200.8, ICP-MS Prep/E200.8, ICP-MS Lead/Copper)

Parameter	Results	Units	MRL	LOD	MCL	DF	Prepared	By	Analyzed	By	Qualifier
Copper Total	0.150	mg/L	0.00100	0.00100	1.3	1	10/16/2025 06:41	ML	10/20/2025 20:10	MMO	
Lead Total	0.00192	mg/L	0.0010	0.0010	0.015	1	10/16/2025 06:41	ML	10/20/2025 20:10	MMO	



PWS_1990012_AC_20251006_LCR Analysis Report
LCRA Environmental Laboratory Services
3505 Montopolis Drive
Austin, TX 78744
Phone (512)730-6022
Fax (512)730-6021

Analytical Results

Client ID: TX1990012	Date Collected: 10/07/2025 05:40	Matrix: Drinking Water
Lab ID: Q2540423004	Date Received: 10/14/2025 12:05	Sample Type: SAMPLE
Sample ID: LCR014	Location: 635 DOVE LANDING	
Project ID: LEAD AND COPPER PROGRAM	Facility: DS01	
	Sample Point: LCR014	

INORGANICS (E200.8, ICP-MS Prep/E200.8, ICP-MS Lead/Copper)

Parameter	Results	Units	MRL	LOD	MCL	DF	Prepared	By	Analyzed	By	Qualifier
Lead Total	<0.0010	mg/L	0.0010	0.0010	0.015	1	10/16/2025 08:41	ML	10/20/2025 20:11	MMO	

INORGANICS (E200.8, ICP-MS Prep/E200.8, ICP-MS Lead/Copper)

Parameter	Results	Units	MRL	LOD	MCL	DF	Prepared	By	Analyzed	By	Qualifier
Copper Total	1.36	mg/L	0.00500	0.00500	1.3	5	10/16/2025 06:41	ML	10/29/2025 19:24	MMO	

Analytical Results

Client ID: TX1990012	Date Collected: 10/06/2025 12:09	Matrix: Drinking Water
Lab ID: Q2540423005	Date Received: 10/14/2025 12:05	Sample Type: SAMPLE
Sample ID: LCR015	Location: 1400 WHEELERS WAY	
Project ID: LEAD AND COPPER PROGRAM	Facility: DS01	
	Sample Point: LCR015	

INORGANICS (E200.8, ICP-MS Prep/E200.8, ICP-MS Lead/Copper)

Parameter	Results	Units	MRL	LOD	MCL	DF	Prepared	By	Analyzed	By	Qualifier
Copper Total	0.0430	mg/L	0.00100	0.00100	1.3	1	10/16/2025 08:41	ML	10/20/2025 20:12	MMO	
Lead Total	<0.0010	mg/L	0.0010	0.0010	0.015	1	10/16/2025 08:41	ML	10/20/2025 20:12	MMO	

Analytical Results

Client ID: TX1990012	Date Collected: 10/07/2025 09:00	Matrix: Drinking Water
Lab ID: Q2540423006	Date Received: 10/14/2025 12:05	Sample Type: SAMPLE
Sample ID: LCR016	Location: 227 PHEASANT HILL	
Project ID: LEAD AND COPPER PROGRAM	Facility: DS01	
	Sample Point: LCR016	

INORGANICS (E200.8, ICP-MS Prep/E200.8, ICP-MS Lead/Copper)

Parameter	Results	Units	MRL	LOD	MCL	DF	Prepared	By	Analyzed	By	Qualifier
Lead Total	0.00116	mg/L	0.0010	0.0010	0.015	1	10/16/2025 06:41	ML	10/20/2025 20:14	MMO	

INORGANICS (E200.8, ICP-MS Prep/E200.8, ICP-MS Lead/Copper)

Parameter	Results	Units	MRL	LOD	MCL	DF	Prepared	By	Analyzed	By	Qualifier
Copper Total	0.741	mg/L	0.00200	0.00200	1.3	2	10/16/2025 06:41	ML	10/29/2025 19:26	MMO	



Analytical Results

Client ID: TX1990012	Date Collected: 10/07/2025 05:30	Matrix: Drinking Water
Lab ID: Q2540423007	Date Received: 10/14/2025 12:05	Sample Type: SAMPLE
Sample ID: LCR017	Location: 200 HORSESHOE BEND	
Project ID: LEAD AND COPPER PROGRAM	Facility: DS01	
	Sample Point: LCR017	

INORGANICS (E200.8, ICP-MS Prep/E200.8, ICP-MS Lead/Copper)

Parameter	Results	Units	MRL	LOD	MCL	DF	Prepared	By	Analyzed	By	Qualifier
Lead Total	<0.0010	mg/L	0.0010	0.0010	0.015	1	10/16/2025 06:41	ML	10/20/2025 20:15	MMO	

INORGANICS (E200.8, ICP-MS Prep/E200.8, ICP-MS Lead/Copper)

Parameter	Results	Units	MRL	LOD	MCL	DF	Prepared	By	Analyzed	By	Qualifier
Copper Total	0.790	mg/L	0.00200	0.00200	1.3	2	10/16/2025 06:41	ML	10/29/2025 19:27	MMO	

Analytical Results

Client ID: TX1990012	Date Collected: 10/06/2025 13:40	Matrix: Drinking Water
Lab ID: Q2540423008	Date Received: 10/14/2025 12:05	Sample Type: SAMPLE
Sample ID: LCR018	Location: 1406 S HWY 205	
Project ID: LEAD AND COPPER PROGRAM	Facility: DS01	
	Sample Point: LCR018	

INORGANICS (E200.8, ICP-MS Prep/E200.8, ICP-MS Lead/Copper)

Parameter	Results	Units	MRL	LOD	MCL	DF	Prepared	By	Analyzed	By	Qualifier
Copper Total	1.24	mg/L	0.00400	0.00400	1.3	4	10/16/2025 06:41	ML	10/29/2025 19:28	MMO	

INORGANICS (E200.8, ICP-MS Prep/E200.8, ICP-MS Lead/Copper)

Parameter	Results	Units	MRL	LOD	MCL	DF	Prepared	By	Analyzed	By	Qualifier
Lead Total	0.00103	mg/L	0.0010	0.0010	0.015	1	10/16/2025 06:41	ML	10/20/2025 20:16	MMO	

Analytical Results

Client ID: TX1990012	Date Collected: 10/07/2025 05:00	Matrix: Drinking Water
Lab ID: Q2540423009	Date Received: 10/14/2025 12:05	Sample Type: SAMPLE
Sample ID: LCR019	Location: 639 WILDERNESS TRAIL	
Project ID: LEAD AND COPPER PROGRAM	Facility: DS01	
	Sample Point: LCR019	

INORGANICS (E200.8, ICP-MS Prep/E200.8, ICP-MS Lead/Copper)

Parameter	Results	Units	MRL	LOD	MCL	DF	Prepared	By	Analyzed	By	Qualifier
Copper Total	0.151	mg/L	0.00100	0.00100	1.3	1	10/16/2025 06:41	ML	10/20/2025 20:18	MMO	
Lead Total	0.00302	mg/L	0.0010	0.0010	0.015	1	10/16/2025 06:41	ML	10/20/2025 20:18	MMO	

Analytical Results

Client ID: TX1990012	Date Collected: 10/07/2025 07:15	Matrix: Drinking Water
Lab ID: Q2540423010	Date Received: 10/14/2025 12:05	Sample Type: SAMPLE
Sample ID: LCR020	Location: 1411 HWY 205	
Project ID: LEAD AND COPPER PROGRAM	Facility: DS01	
	Sample Point: LCR020	

INORGANICS (E200.8, ICP-MS Prep/E200.8, ICP-MS Lead/Copper)

Parameter	Results	Units	MRL	LOD	MCL	DF	Prepared	By	Analyzed	By	Qualifier
Lead Total	0.00145	mg/L	0.0010	0.0010	0.015	1	10/16/2025 06:41	ML	10/20/2025 20:19	MMO	

INORGANICS (E200.8, ICP-MS Prep/E200.8, ICP-MS Lead/Copper)

Parameter	Results	Units	MRL	LOD	MCL	DF	Prepared	By	Analyzed	By	Qualifier
Copper Total	1.22	mg/L	0.00400	0.00400	1.3	4	10/16/2025 06:41	ML	10/29/2025 19:30	MMO	



PWS_1990012_AC_20251006_LCR Analysis Report
LCRA Environmental Laboratory Services
3505 Montopolis Drive
Austin, TX 78744
Phone (512)730-6022
Fax (512)730-6021

Analytical Results

Client ID: TX1990012	Date Collected: 10/07/2025 14:45	Matrix: Drinking Water
Lab ID: Q2540423011	Date Received: 10/14/2025 12:05	Sample Type: SAMPLE
Sample ID: LCR031	Location: 904 HAMILTON CT	
Project ID: LEAD AND COPPER PROGRAM	Facility: DS01	
	Sample Point: LCR031	

INORGANICS (E200.8, ICP-MS Prep/E200.8, ICP-MS Lead/Copper)

Parameter	Results	Units	MRL	LOD	MCL	DF	Prepared	By	Analyzed	By	Qualifier
Copper Total	0.0349	mg/L	0.00100	0.00100	1.3	1	10/16/2025 06:41	ML	10/20/2025 20:30	MMO	
Lead Total	<0.0010	mg/L	0.0010	0.0010	0.015	1	10/16/2025 06:41	ML	10/20/2025 20:30	MMO	



PWS_1990012_AC_20251006_LCR Analysis Report
LCRA Environmental Laboratory Services
3505 Montopolis Drive
Austin, TX 78744
Phone (512)730-6022
Fax (512)730-6021

Analytical Results

Client ID: TX1990012	Date Collected: 10/08/2025 07:15	Matrix: Drinking Water
Lab ID: Q2540423012	Date Received: 10/14/2025 12:05	Sample Type: SAMPLE
Sample ID: LCR032	Location: 1032 KINGSBRIDGE	
Project ID: LEAD AND COPPER PROGRAM	Facility: DS01	
	Sample Point: LCR032	

INORGANICS (E200.8, ICP-MS Prep/E200.8, ICP-MS Lead/Copper)

Parameter	Results	Units	MRL	LOD	MCL	DF	Prepared	By	Analyzed	By	Qualifier
Copper Total	0.0948	mg/L	0.00100	0.00100	1.3	1	10/16/2025 06:41	ML	10/20/2025 20:32	MMO	
Lead Total	<0.0010	mg/L	0.0010	0.0010	0.015	1	10/16/2025 06:41	ML	10/20/2025 20:32	MMO	



PWS_1990012_AC_20251006_LCR Analysis Report
LCRA Environmental Laboratory Services
3505 Montopolis Drive
Austin, TX 78744
Phone (512)730-6022
Fax (512)730-6021

Analytical Results

Client ID: TX1990012	Date Collected: 10/07/2025 14:15	Matrix: Drinking Water
Lab ID: Q2540423013	Date Received: 10/14/2025 12:05	Sample Type: SAMPLE
Sample ID: LCR033	Location: 1497 S SH 205	
Project ID: LEAD AND COPPER PROGRAM	Facility: DS01	
	Sample Point: LCR033	

INORGANICS (E200.8, ICP-MS Prep/E200.8, ICP-MS Lead/Copper)

Parameter	Results	Units	MRL	LOD	MCL	DF	Prepared	By	Analyzed	By	Qualifier
Copper Total	0.0713	mg/L	0.00100	0.00100	1.3	1	10/16/2025 08:41	ML	10/20/2025 20:33	MMO	
Lead Total	<0.0010	mg/L	0.0010	0.0010	0.015	1	10/16/2025 08:41	ML	10/20/2025 20:33	MMO	

Analytical Results

Client ID: TX1990012	Date Collected: 10/08/2025 06:45	Matrix: Drinking Water
Lab ID: Q2540423014	Date Received: 10/14/2025 12:05	Sample Type: SAMPLE
Sample ID: LCR034	Location: 312 BESTOWAL	
Project ID: LEAD AND COPPER PROGRAM	Facility: DS01	
	Sample Point: LCR034	

INORGANICS (E200.8, ICP-MS Prep/E200.8, ICP-MS Lead/Copper)

Parameter	Results	Units	MRL	LOD	MCL	DF	Prepared	By	Analyzed	By	Qualifier
Copper Total	0.00800	mg/L	0.00100	0.00100	1.3	1	10/16/2025 08:41	ML	10/20/2025 20:34	MMO	
Lead Total	<0.0010	mg/L	0.0010	0.0010	0.015	1	10/16/2025 08:41	ML	10/20/2025 20:34	MMO	

Analytical Results

Client ID: TX1990012	Date Collected: 10/09/2025 10:00	Matrix: Drinking Water
Lab ID: Q2540423015	Date Received: 10/14/2025 12:05	Sample Type: SAMPLE
Sample ID: LCR035	Location: 410 E FM 550	
Project ID: LEAD AND COPPER PROGRAM	Facility: DS01	
	Sample Point: LCR035	

INORGANICS (E200.8, ICP-MS Prep/E200.8, ICP-MS Lead/Copper)

Parameter	Results	Units	MRL	LOD	MCL	DF	Prepared	By	Analyzed	By	Qualifier
Copper Total	0.607	mg/L	0.00200	0.00200	1.3	2	10/16/2025 06:41	ML	10/29/2025 19:31	MMO	

INORGANICS (E200.8, ICP-MS Prep/E200.8, ICP-MS Lead/Copper)

Parameter	Results	Units	MRL	LOD	MCL	DF	Prepared	By	Analyzed	By	Qualifier
Lead Total	<0.0010	mg/L	0.0010	0.0010	0.015	1	10/16/2025 06:41	ML	10/20/2025 20:36	MMO	



PWS_1990012_AC_20251006_LCR Analysis Report
LCRA Environmental Laboratory Services
3505 Montopolis Drive
Austin, TX 78744
Phone (512)730-6022
Fax (512)730-6021

Analytical Results

Client ID: TX1990012	Date Collected: 10/08/2025 14:57	Matrix: Drinking Water
Lab ID: Q2540423016	Date Received: 10/14/2025 12:05	Sample Type: SAMPLE
Sample ID: LCR036	Location: 1540 RIPASSO WAY	
Project ID: LEAD AND COPPER PROGRAM	Facility: DS01	
	Sample Point: LCR036	

INORGANICS (E200.8, ICP-MS Prep/E200.8, ICP-MS Lead/Copper)

Parameter	Results	Units	MRL	LOD	MCL	DF	Prepared	By	Analyzed	By	Qualifier
Copper Total	0.0109	mg/L	0.00100	0.00100	1.3	1	10/16/2025 06:41	ML	10/20/2025 20:37	MMO	
Lead Total	<0.0010	mg/L	0.0010	0.0010	0.015	1	10/16/2025 06:41	ML	10/20/2025 20:37	MMO	



PWS_1990012_AC_20251006_LCR Analysis Report
LCRA Environmental Laboratory Services
3505 Montopolis Drive
Austin, TX 78744
Phone (512)730-6022
Fax (512)730-6021

Analytical Results

Client ID: TX1990012	Date Collected: 10/09/2025 06:41	Matrix: Drinking Water
Lab ID: Q2540423017	Date Received: 10/14/2025 12:05	Sample Type: SAMPLE
Sample ID: LCR037	Location: 1332 SOMERSET LN	
Project ID: LEAD AND COPPER PROGRAM	Facility: DS01	
	Sample Point: LCR037	

INORGANICS (E200.8, ICP-MS Prep/E200.8, ICP-MS Lead/Copper)

Parameter	Results	Units	MRL	LOD	MCL	DF	Prepared	By	Analyzed	By	Qualifier
Copper Total	0.144	mg/L	0.00100	0.00100	1.3	1	10/16/2025 06:41	ML	10/20/2025 20:39	MMO	
Lead Total	<0.0010	mg/L	0.0010	0.0010	0.015	1	10/16/2025 06:41	ML	10/20/2025 20:39	MMO	

Analytical Results

Client ID: TX1990012	Date Collected: 10/07/2025 13:40	Matrix: Drinking Water
Lab ID: Q2540423018	Date Received: 10/14/2025 12:05	Sample Type: SAMPLE
Sample ID: LCR038	Location: 484 SAVANNA HILL	
Project ID: LEAD AND COPPER PROGRAM	Facility: DS01	
	Sample Point: LCR038	

INORGANICS (E200.8, ICP-MS Prep/E200.8, ICP-MS Lead/Copper)

Parameter	Results	Units	MRL	LOD	MCL	DF	Prepared	By	Analyzed	By	Qualifier
Copper Total	0.145	mg/L	0.00100	0.00100	1.3	1	10/16/2025 06:41	ML	10/20/2025 20:40	MMO	
Lead Total	0.00137	mg/L	0.0010	0.0010	0.015	1	10/16/2025 06:41	ML	10/20/2025 20:40	MMO	



PWS_1990012_AC_20251006_LCR Analysis Report
LCRA Environmental Laboratory Services
3505 Montopolis Drive
Austin, TX 78744
Phone (512)730-6022
Fax (512)730-6021

Analytical Results

Client ID: TX1990012	Date Collected: 10/07/2025 12:00	Matrix: Drinking Water
Lab ID: Q2540423019	Date Received: 10/14/2025 12:05	Sample Type: SAMPLE
Sample ID: LCR039	Location: 108 ROSE MARIE LN	
Project ID: LEAD AND COPPER PROGRAM	Facility: DS01	
	Sample Point: LCR039	

INORGANICS (E200.8, ICP-MS Prep/E200.8, ICP-MS Lead/Copper)

Parameter	Results	Units	MRL	LOD	MCL	DF	Prepared	By	Analyzed	By	Qualifier
Copper Total	0.192	mg/L	0.00100	0.00100	1.3	1	10/16/2025 06:41	ML	10/20/2025 20:41	MMO	
Lead Total	<0.0010	mg/L	0.0010	0.0010	0.015	1	10/16/2025 06:41	ML	10/20/2025 20:41	MMO	



Analytical Results

Client ID: TX1990012	Date Collected: 10/08/2025 07:23	Matrix: Drinking Water
Lab ID: Q2540423020	Date Received: 10/14/2025 12:05	Sample Type: SAMPLE
Sample ID: LCR040	Location: 403 TRAVIS LN	
Project ID: LEAD AND COPPER PROGRAM	Facility: DS01	
	Sample Point: LCR040	

INORGANICS (E200.8, ICP-MS Prep/E200.8, ICP-MS Lead/Copper)

Parameter	Results	Units	MRL	LOD	MCL	DF	Prepared	By	Analyzed	By	Qualifier
Lead Total	<0.0010	mg/L	0.0010	0.0010	0.015	1	10/16/2025 06:41	ML	10/20/2025 20:43	MMO	

INORGANICS (E200.8, ICP-MS Prep/E200.8, ICP-MS Lead/Copper)

Parameter	Results	Units	MRL	LOD	MCL	DF	Prepared	By	Analyzed	By	Qualifier
Copper Total	0.660	mg/L	0.00200	0.00200	1.3	2	10/16/2025 06:41	ML	10/29/2025 19:33	MMO	



Quality Control Results

QC Batch: MET/11354
Preparation Method: E200.8, ICP-MS Lead/Copper
Analysis Method: E200.8, ICP-MS Lead/Copper
Associated Lab IDs: Q2540423001, Q2540423002, Q2540423003, Q2540423004, Q2540423005, Q2540423006, Q2540423007, Q2540423008, Q2540423009, Q2540423010, Q2540423011, Q2540423012, Q2540423013, Q2540423014, Q2540423015, Q2540423016, Q2540423017, Q2540423018, Q2540423019, Q2540423020

Method Reporting Limit Check (2319325)

Parameter	Units	Spiked Amount	Spike Result	Spike Recovery%	Control Limits %	Qualifier
Copper Total	mg/L	0.001	0.0013	129.0	50 - 150	
Lead Total	mg/L	0.001	0.001	104.0	50 - 150	

Quality Control Results

QC Batch: MET/11354 **Analysis Method:** E200.8, ICP-MS Lead/Copper
Preparation Method: E200.8, ICP-MS Prep
Associated Lab IDs: Q2540423001, Q2540423002, Q2540423003, Q2540423004, Q2540423005, Q2540423006, Q2540423007, Q2540423008, Q2540423009, Q2540423010

Laboratory Fortified Blank (2317558); Lab Fortified Blank Duplicate (2317559)

Parameter	Units	Spiked Amount	Spike Result	%Spike Recovery	Control Limits %	Duplicate Result	%Duplicate Recovery	RPD	RPD Limit	Qualifier
Copper Total	mg/L	0.05	0.0503	101.0	85 - 115	0.0493	98.5	2.01	20	
Lead Total	mg/L	0.05	0.0494	98.7	85 - 115	0.0482	96.5	2.46	20	

Laboratory Fortified Matrix (2317696); Lab Fortified Matrix Duplicate (2317697); Original: Q2540423001

Parameter	Units	Spiked Amount	Spike Result	%Spike Recovery	Control Limits %	Duplicate Result	%Duplicate Recovery	RPD	RPD Limit	Qualifier
Copper Total	mg/L	0.05	0.119	82.6	70 - 130	0.122	90.3	2.49	20	
Lead Total	mg/L	0.05	0.0468	92.6	70 - 130	0.0491	97.1	4.8	20	

Laboratory Reagent Blank(2317557)

Parameter	Units	Results	MRL	LOD	Qualifier
Copper Total	mg/L	<0.00100	0.001	0.001	
Lead Total	mg/L	<0.0010	0.001	0.001	

Quality Control Results

QC Batch: MET/11354 Analysis Method: E200.8, ICP-MS Lead/Copper
Preparation Method: E200.8, ICP-MS Prep
Associated Lab IDs: Q2540423011, Q2540423012, Q2540423013, Q2540423014, Q2540423015, Q2540423016, Q2540423017, Q2540423018, Q2540423019, Q2540423020

Laboratory Reagent Blank(2317698)

Parameter	Units	Results	MRL	LOD	Qualifier
Copper Total	mg/L	<0.00100	0.001	0.001	
Lead Total	mg/L	<0.0010	0.001	0.001	

Laboratory Fortified Matrix (2317701); Lab Fortified Matrix Duplicate (2317702); Original: Q2540423011

Parameter	Units	Spiked Amount	Spike Result	%Spike Recovery	Control Limits %	Duplicate Result	%Duplicate Recovery	RPD	RPD Limit	Qualifier
Copper Total	mg/L	0.05	0.0803	90.9	70 - 130	0.0778	85.8	3.16	20	
Lead Total	mg/L	0.05	0.0504	100.0	70 - 130	0.047	93.4	6.98	20	

Laboratory Fortified Blank (2317699); Lab Fortified Blank Duplicate (2317700)

Parameter	Units	Spiked Amount	Spike Result	%Spike Recovery	Control Limits %	Duplicate Result	%Duplicate Recovery	RPD	RPD Limit	Qualifier
Copper Total	mg/L	0.05	0.0506	101.0	85 - 115	0.0498	99.7	1.59	20	
Lead Total	mg/L	0.05	0.0493	98.6	85 - 115	0.0491	98.2	0.407	20	

Quality Control Results

QC Batch: MET/11368
Preparation Method: E200.8, ICP-MS Lead/Copper
Analysis Method: E200.8, ICP-MS Lead/Copper
Associated Lab IDs: Q2540423004, Q2540423006, Q2540423007, Q2540423008, Q2540423010, Q2540423015, Q2540423020

Method Reporting Limit Check (2323481)

Parameter	Units	Spiked Amount	Spike Result	Spike Recovery%	Control Limits %	Qualifier
Copper Total	mg/L	0.001	0.0011	107.0	50 - 150	

QC Cross Reference

Lab ID	Sample ID	Prep Batch	Prep Method
MET/11354 - E200.8, ICP-MS Lead/Copper			
Q2540423001	LCR003	MEP/14789	E200.8, ICP-MS Prep
Q2540423002	LCR012	MEP/14789	E200.8, ICP-MS Prep
Q2540423003	LCR013	MEP/14789	E200.8, ICP-MS Prep
Q2540423004	LCR014	MEP/14789	E200.8, ICP-MS Prep
Q2540423005	LCR015	MEP/14789	E200.8, ICP-MS Prep
Q2540423006	LCR016	MEP/14789	E200.8, ICP-MS Prep
Q2540423007	LCR017	MEP/14789	E200.8, ICP-MS Prep
Q2540423008	LCR018	MEP/14789	E200.8, ICP-MS Prep
Q2540423009	LCR019	MEP/14789	E200.8, ICP-MS Prep
Q2540423010	LCR020	MEP/14789	E200.8, ICP-MS Prep
Q2540423011	LCR031	MEP/14789	E200.8, ICP-MS Prep
Q2540423012	LCR032	MEP/14789	E200.8, ICP-MS Prep
Q2540423013	LCR033	MEP/14789	E200.8, ICP-MS Prep
Q2540423014	LCR034	MEP/14789	E200.8, ICP-MS Prep
Q2540423015	LCR035	MEP/14789	E200.8, ICP-MS Prep
Q2540423016	LCR036	MEP/14789	E200.8, ICP-MS Prep
Q2540423017	LCR037	MEP/14789	E200.8, ICP-MS Prep
Q2540423018	LCR038	MEP/14789	E200.8, ICP-MS Prep
Q2540423019	LCR039	MEP/14789	E200.8, ICP-MS Prep
Q2540423020	LCR040	MEP/14789	E200.8, ICP-MS Prep
MET/11368 - E200.8, ICP-MS Lead/Copper			
Q2540423004	LCR014	MEP/14789	E200.8, ICP-MS Prep
Q2540423006	LCR016	MEP/14789	E200.8, ICP-MS Prep
Q2540423007	LCR017	MEP/14789	E200.8, ICP-MS Prep
Q2540423008	LCR018	MEP/14789	E200.8, ICP-MS Prep
Q2540423010	LCR020	MEP/14789	E200.8, ICP-MS Prep
Q2540423015	LCR035	MEP/14789	E200.8, ICP-MS Prep
Q2540423020	LCR040	MEP/14789	E200.8, ICP-MS Prep

End of Report

TEXAS COMMISSION ON ENVIRONMENTAL QUALITY
LEAD AND COPPER RULE MONITORING FORM (LCRMF) 20683

COMPLETED BY PWS (OR AGENT)		COMPLETED BY LABORATORY	
PWS Name:	RCH WSC	Laboratory Name:	LCRA Environmental Laboratory Services
PWS ID #:	TX 1990012	TCEQ Laboratory ID #:	1104704216
PWS Address:	P.O. Box 2318 Rockwall TX 75087	Laboratory Address:	3505 Montopolis Drive, Austin, TX 78744
PWS Contact Name:	Curtis Logan	Laboratory Contact Name:	Jason Woods
PWS Contact Phone #:	903-477-0501	Laboratory Contact Phone #:	(877) 362-5272
PWS Tap Sample Checklist (✓)		Sample Condition on Receipt	
☒ Samples filled to 1 Liter volume	☒ Samples taken from a frequently used inside tap	Samples documented upon receipt (Y or N)	Y
☒ Samples collected from cold water tap(s)	☒ Taps were unused for 8 hours prior to collection	Samples collected in 1 Liter labeled containers (Y or N)	Y
☒ Sample containers with labels	☒ Samples delivered to lab within 14 days of collection	Samples filled to 1 Liter volume (Y or N)	Y
		Actual sample temperature (°C)	25.3
		Controlled sample temperature (°C)	26.2
		Thermometer ID #:	121K

Facility ID (entry point (PWS/DO#) or distribution (DO#))	Sample Point ID (entry point (PWS/DO#) or distribution (DO#))	Sample Location (address of sample point)	Sample Faucet Last Used Date (MM/DD/YY)	Sample Faucet Last Used Time-24 Hr (HH:MM)	Sample Collected Date (MM/DD/YY)	Sample Collection Time-24 Hr (HH:MM)	Replacement Indicator (Y)	Original Sample ID#	Original Collection Date (MM/DD/YY)	Lab Sample ID	Laboratory Preservation Date (MM/DD/YY)	Laboratory Preservation Time- 24 Hr (HH:MM)	Sample Register Code (if applicable)
DS01	LCR001	2151 Chisholm Tr	10/07/25	1000	10/06/25	1430				Q2540527	10/12/25	17:44	
DS01	LCR002	571 McDonald Rd	10/05/25	1030	10/06/25	0950				002			
DS01	LCR004	2101 FM 1135/Bathroom	10/05/25	1100	10/06/25	1012				003			
DS01	LCR005	120 Meadow Dr	10/05/25	2200	10/06/25	1130				004			
DS01	LCR006	1251 English	10/05/25	1000	10/06/25	1157				005			
DS01	LCR007	661 Meadow Dr	10/05/25	1800	10/07/25	0500				006			
DS01	LCR008	2004 Hebren Cir	10/05/25	0500	10/06/25	1100				007			
DS01	LCR009	250 League Rd	10/06/25	1700	10/07/25	0918				008			
DS01	LCR010	14565 FM 548	10/05/25	1800	10/06/25	1147				009			
DS01	LCR011	561 HWY 205 S	10/06/25	2120	10/07/25	0806				010			

Sample Collection Acknowledgement		Laboratory Comments	
I acknowledge that the information on this form is true and correct and items selected for sampling follow the approved TCEQ Form 20683 and the PWS Monitoring Plan. Fabrication of this form or tampering with water samples is a crime punishable under state and/or federal law. (Texas Penal Code, Title 9, Chapter 37, Section 37.10)		 0438174 719840	
Name of Authorized PWS Representative (Print)	PWS Representative Signature	Organization	
Curtis Logan	Curtis Logan		
CHAIN OF CUSTODY (COC)			
Relinquished By (Signature)	Date/Time	Relinquished By Counter (Signature)	Date/Time
Curtis Logan	10-10-25 0800		
Received By Counter (Signature)	Date/Time	Received By Lab (Signature)	Date/Time

TCEQ 20683 (Rev. 11/2023)

0013 2681 8091

10-13-25 3:45
Page 1 of 2



PWS_1990012_AC_20251006_LCR Analysis Report
LCRA Environmental Laboratory Services
3505 Montopolis Drive
Austin, TX 78744
Phone (512)730-6022
Fax (512)730-6021

October 30, 2025

CURTIS LOGAN
4800 LOFLAND CIRCLE
Rockwall, TX 75032
CLOGAN@RCHWATERSUPPLY.COM

RE: Final Analytical Report Q2540322
Attn: CURTIS LOGAN

Enclosed are the analytical results for sample(s) received by LCRA Environmental Laboratory Services. Results reported herein conform to the most current NELAP standards, where applicable, unless otherwise narrated in the body of the report. This final report provides results related only to the sample(s) as received for the above referenced work order.

Thank you for selecting ELS for your analytical needs. If you have any questions regarding this report, please contact us at (512) 730-6022 or environmental.lab@lcra.org. We look forward to assisting you again.

Authorized for release by:

Rhys Woodruff
Quality Assurance Specialist
Rhys.woodruff@lcra.org



Enclosures:
CC:ROBIN MAYALL

Workorder: Q2540322
Workorder Description: TX1990012_LCR_10_14_2025
Client: RCH WSC
Profile: LEAD AND COPPER PROGRAM
Sampled By: RESIDENT

Report To: CURTIS LOGAN
4800 LOFLAND CIRCLE
Rockwall, TX 75032

Sample Summary

Lab ID	Sample ID	Matrix	Method	Date Collected	Date Received	Analytes Reported
Q2540322001	LCR001	DW	E200.8, ICP-MS Lead/Copper	10/08/2025 14:30	10/13/2025 15:45	2
Q2540322002	LCR002	DW	E200.8, ICP-MS Lead/Copper	10/06/2025 09:50	10/13/2025 15:45	2
Q2540322003	LCR004	DW	E200.8, ICP-MS Lead/Copper	10/06/2025 10:12	10/13/2025 15:45	2
Q2540322004	LCR005	DW	E200.8, ICP-MS Lead/Copper	10/06/2025 11:30	10/13/2025 15:45	2
Q2540322005	LCR006	DW	E200.8, ICP-MS Lead/Copper	10/06/2025 11:57	10/13/2025 15:45	2
Q2540322006	LCR007	DW	E200.8, ICP-MS Lead/Copper	10/07/2025 05:00	10/13/2025 15:45	2
Q2540322007	LCR008	DW	E200.8, ICP-MS Lead/Copper	10/06/2025 11:00	10/13/2025 15:45	2
Q2540322008	LCR009	DW	E200.8, ICP-MS Lead/Copper	10/07/2025 09:18	10/13/2025 15:45	2
Q2540322009	LCR010	DW	E200.8, ICP-MS Lead/Copper	10/06/2025 11:47	10/13/2025 15:45	2
Q2540322010	LCR011	DW	E200.8, ICP-MS Lead/Copper	10/07/2025 08:05	10/13/2025 15:45	2

Report Definitions

MRL - Minimum Reporting Limit
LOD - Limit of Detection
ML - Maximum Limit - Client Specified
MCL - Maximum Contaminant Level
LOQ - Limit of Quantitation - Client Specified
DF - Dilution Factor
(S) - Surrogate Spike
MDL - Method Detection Limit
RPD - Relative Percent Difference

Qualifier Definitions

J - Analyte detected below quantitation limit
R - RPD outside duplicate precision limit
S - Spike recovery outside limit
B - Analyte detected in method blank
N - Not Accredited
M - Analyte Detected Above Maximum Contaminant Level
SL - Spike Recovery Low
SH - Spike Recovery High
H - Analyzed Past Hold Time
CR - Confirmed Result
CH - Result confirmed by historical data



PWS_1990012_AC_20251006_LCR Analysis Report
LCRA Environmental Laboratory Services
3505 Montopolis Drive
Austin, TX 78744
Phone (512)730-6022
Fax (512)730-6021

Workorder Summary



PWS_1990012_AC_20251006_LCR Analysis Report
LCRA Environmental Laboratory Services
3505 Montopolis Drive
Austin, TX 78744
Phone (512)730-6022
Fax (512)730-6021

Analytical Results

Client ID:	TX1990012	Date Collected:	10/08/2025 14:30	Matrix:	Drinking Water
Lab ID:	Q2540322001	Date Received:	10/13/2025 15:45	Sample Type:	SAMPLE
Sample ID:	LCR001	Location:	2151 CHISHOLM TL		
Project ID:	LEAD AND COPPER PROGRAM	Facility:	DS01		
		Sample Point:	LCR001		

INORGANICS (E200.8, ICP-MS Prep/E200.8, ICP-MS Lead/Copper)

Parameter	Results	Units	MRL	LOD	MCL	DF	Prepared	By	Analyzed	By	Qualifier
Copper Total	0.310	mg/L	0.00100	0.00100	1.3	1	10/15/2025 14:49	ML	10/20/2025 19:47	MMO	
Lead Total	<0.0010	mg/L	0.0010	0.0010	0.015	1	10/15/2025 14:49	ML	10/20/2025 19:47	MMO	

Analytical Results

Client ID: TX1990012	Date Collected: 10/06/2025 09:50	Matrix: Drinking Water
Lab ID: Q2540322002	Date Received: 10/13/2025 15:45	Sample Type: SAMPLE
Sample ID: LCR002	Location: 571 MCDONALD RD	
Project ID: LEAD AND COPPER PROGRAM	Facility: DS01	
	Sample Point: LCR002	

INORGANICS (E200.8, ICP-MS Prep/E200.8, ICP-MS Lead/Copper)

Parameter	Results	Units	MRL	LOD	MCL	DF	Prepared	By	Analyzed	By	Qualifier
Copper Total	1.15	mg/L	0.00400	0.00400	1.3	4	10/15/2025 14:49	ML	10/29/2025 19:20	MMO	

INORGANICS (E200.8, ICP-MS Prep/E200.8, ICP-MS Lead/Copper)

Parameter	Results	Units	MRL	LOD	MCL	DF	Prepared	By	Analyzed	By	Qualifier
Lead Total	0.00217	mg/L	0.0010	0.0010	0.015	1	10/15/2025 14:49	ML	10/20/2025 19:49	MMO	

Analytical Results

Client ID: TX1990012	Date Collected: 10/06/2025 10:12	Matrix: Drinking Water
Lab ID: Q2540322003	Date Received: 10/13/2025 15:45	Sample Type: SAMPLE
Sample ID: LCR004	Location: 2101 FM 1139 BATHROOM	
Project ID: LEAD AND COPPER PROGRAM	Facility: DS01	
	Sample Point: LCR004	

INORGANICS (E200.8, ICP-MS Prep/E200.8, ICP-MS Lead/Copper)

Parameter	Results	Units	MRL	LOD	MCL	DF	Prepared	By	Analyzed	By	Qualifier
Copper Total	0.420	mg/L	0.00100	0.00100	1.3	1	10/15/2025 14:49	ML	10/20/2025 19:50	MMO	
Lead Total	0.00156	mg/L	0.0010	0.0010	0.015	1	10/15/2025 14:49	ML	10/20/2025 19:50	MMO	



Analytical Results

Client ID: TX1990012	Date Collected: 10/06/2025 11:30	Matrix: Drinking Water
Lab ID: Q2540322004	Date Received: 10/13/2025 15:45	Sample Type: SAMPLE
Sample ID: LCR005	Location: 120 MEADOW DR	
Project ID: LEAD AND COPPER PROGRAM	Facility: DS01	
	Sample Point: LCR005	

INORGANICS (E200.8, ICP-MS Prep/E200.8, ICP-MS Lead/Copper)

Parameter	Results	Units	MRL	LOD	MCL	DF	Prepared	By	Analyzed	By	Qualifier
Copper Total	0.193	mg/L	0.00100	0.00100	1.3	1	10/15/2025 14:49	ML	10/20/2025 19:52	MMO	
Lead Total	0.00217	mg/L	0.0010	0.0010	0.015	1	10/15/2025 14:49	ML	10/20/2025 19:52	MMO	



PWS_1990012_AC_20251006_LCR Analysis Report
LCRA Environmental Laboratory Services
3505 Montopolis Drive
Austin, TX 78744
Phone (512)730-6022
Fax (512)730-6021

Analytical Results

Client ID: TX1990012	Date Collected: 10/06/2025 11:57	Matrix: Drinking Water
Lab ID: Q2540322005	Date Received: 10/13/2025 15:45	Sample Type: SAMPLE
Sample ID: LCR006	Location: 1251 ENGLISH	
Project ID: LEAD AND COPPER PROGRAM	Facility: DS01	
	Sample Point: LCR006	

INORGANICS (E200.8, ICP-MS Prep/E200.8, ICP-MS Lead/Copper)

Parameter	Results	Units	MRL	LOD	MCL	DF	Prepared	By	Analyzed	By	Qualifier
Copper Total	0.365	mg/L	0.00100	0.00100	1.3	1	10/15/2025 14:49	ML	10/20/2025 19:53	MMO	
Lead Total	<0.0010	mg/L	0.0010	0.0010	0.015	1	10/15/2025 14:49	ML	10/20/2025 19:53	MMO	

Analytical Results

Client ID: TX1990012	Date Collected: 10/07/2025 05:00	Matrix: Drinking Water
Lab ID: Q2540322006	Date Received: 10/13/2025 15:45	Sample Type: SAMPLE
Sample ID: LCR007	Location: 861 MEADOW DR	
Project ID: LEAD AND COPPER PROGRAM	Facility: DS01	
	Sample Point: LCR007	

INORGANICS (E200.8, ICP-MS Prep/E200.8, ICP-MS Lead/Copper)

Parameter	Results	Units	MRL	LOD	MCL	DF	Prepared	By	Analyzed	By	Qualifier
Copper Total	0.373	mg/L	0.00100	0.00100	1.3	1	10/15/2025 14:49	ML	10/20/2025 19:54	MMO	
Lead Total	<0.0010	mg/L	0.0010	0.0010	0.015	1	10/15/2025 14:49	ML	10/20/2025 19:54	MMO	



PWS_1990012_AC_20251006_LCR Analysis Report
LCRA Environmental Laboratory Services
3505 Montopolis Drive
Austin, TX 78744
Phone (512)730-6022
Fax (512)730-6021

Analytical Results

Client ID: TX1990012	Date Collected: 10/06/2025 11:00	Matrix: Drinking Water
Lab ID: Q2540322007	Date Received: 10/13/2025 15:45	Sample Type: SAMPLE
Sample ID: LCR008	Location: 2004 HEBRON CIR	
Project ID: LEAD AND COPPER PROGRAM	Facility: DS01	
	Sample Point: LCR008	

INORGANICS (E200.8, ICP-MS Prep/E200.8, ICP-MS Lead/Copper)

Parameter	Results	Units	MRL	LOD	MCL	DF	Prepared	By	Analyzed	By	Qualifier
Copper Total	0.186	mg/L	0.00100	0.00100	1.3	1	10/15/2025 14:49	ML	10/20/2025 19:56	MMO	
Lead Total	<0.0010	mg/L	0.0010	0.0010	0.015	1	10/15/2025 14:49	ML	10/20/2025 19:56	MMO	



PWS_1990012_AC_20251006_LCR Analysis Report
LCRA Environmental Laboratory Services
3505 Montopolis Drive
Austin, TX 78744
Phone (512)730-6022
Fax (512)730-6021

Analytical Results

Client ID: TX1990012	Date Collected: 10/07/2025 09:18	Matrix: Drinking Water
Lab ID: Q2540322008	Date Received: 10/13/2025 15:45	Sample Type: SAMPLE
Sample ID: LCR009	Location: 250 LEAGUE RD	
Project ID: LEAD AND COPPER PROGRAM	Facility: DS01	
	Sample Point: LCR009	

INORGANICS (E200.8, ICP-MS Prep/E200.8, ICP-MS Lead/Copper)

Parameter	Results	Units	MRL	LOD	MCL	DF	Prepared	By	Analyzed	By	Qualifier
Lead Total	<0.0010	mg/L	0.0010	0.0010	0.015	1	10/15/2025 14:49	ML	10/20/2025 19:57	MMO	

INORGANICS (E200.8, ICP-MS Prep/E200.8, ICP-MS Lead/Copper)

Parameter	Results	Units	MRL	LOD	MCL	DF	Prepared	By	Analyzed	By	Qualifier
Copper Total	0.893	mg/L	0.00400	0.00400	1.3	4	10/15/2025 14:49	ML	10/29/2025 19:22	MMO	

QC Cross Reference

Lab ID	Sample ID	Prep Batch	Prep Method
MET/11354 - E200.8, ICP-MS Lead/Copper			
Q2540322001	LCR001	MEP/14789	E200.8, ICP-MS Prep
Q2540322002	LCR002	MEP/14789	E200.8, ICP-MS Prep
Q2540322003	LCR004	MEP/14789	E200.8, ICP-MS Prep
Q2540322004	LCR005	MEP/14789	E200.8, ICP-MS Prep
Q2540322005	LCR006	MEP/14789	E200.8, ICP-MS Prep
Q2540322006	LCR007	MEP/14789	E200.8, ICP-MS Prep
Q2540322007	LCR008	MEP/14789	E200.8, ICP-MS Prep
Q2540322008	LCR009	MEP/14789	E200.8, ICP-MS Prep
Q2540322009	LCR010	MEP/14789	E200.8, ICP-MS Prep
Q2540322010	LCR011	MEP/14789	E200.8, ICP-MS Prep
MET/11368 - E200.8, ICP-MS Lead/Copper			
Q2540322002	LCR002	MEP/14789	E200.8, ICP-MS Prep
Q2540322008	LCR009	MEP/14789	E200.8, ICP-MS Prep
Q2540322009	LCR010	MEP/14789	E200.8, ICP-MS Prep

End of Report



PWS_1990012_AC_20251006_LCR Analysis Report
LCRA Environmental Laboratory Services
3505 Montopolis Drive
Austin, TX 78744
Phone (512)730-6022
Fax (512)730-6021

Analytical Results

Client ID: TX1990012	Date Collected: 10/06/2025 11:47	Matrix: Drinking Water
Lab ID: Q2540322009	Date Received: 10/13/2025 15:45	Sample Type: SAMPLE
Sample ID: LCR010	Location: 14565 FM 548	
Project ID: LEAD AND COPPER PROGRAM	Facility: DS01	
	Sample Point: LCR010	

INORGANICS (E200.8, ICP-MS Prep/E200.8, ICP-MS Lead/Copper)

Parameter	Results	Units	MRL	LOD	MCL	DF	Prepared	By	Analyzed	By	Qualifier
Lead Total	0.00117	mg/L	0.0010	0.0010	0.015	1	10/15/2025 14:49	ML	10/20/2025 19:58	MMO	

INORGANICS (E200.8, ICP-MS Prep/E200.8, ICP-MS Lead/Copper)

Parameter	Results	Units	MRL	LOD	MCL	DF	Prepared	By	Analyzed	By	Qualifier
Copper Total	0.650	mg/L	0.00200	0.00200	1.3	2	10/15/2025 14:49	ML	10/29/2025 19:23	MMO	



PWS_1990012_AC_20251006_LCR Analysis Report
LCRA Environmental Laboratory Services
3505 Montopolis Drive
Austin, TX 78744
Phone (512)730-6022
Fax (512)730-6021

Analytical Results

Client ID: TX1990012	Date Collected: 10/07/2025 08:05	Matrix: Drinking Water
Lab ID: Q2540322010	Date Received: 10/13/2025 15:45	Sample Type: SAMPLE
Sample ID: LCR011	Location: 561 HWY 205 S	
Project ID: LEAD AND COPPER PROGRAM	Facility: DS01	
	Sample Point: LCR011	

INORGANICS (E200.8, ICP-MS Prep/E200.8, ICP-MS Lead/Copper)

Parameter	Results	Units	MRL	LOD	MCL	DF	Prepared	By	Analyzed	By	Qualifier
Copper Total	0.505	mg/L	0.00100	0.00100	1.3	1	10/15/2025 14:49	ML	10/20/2025 20:00	MMO	
Lead Total	<0.0010	mg/L	0.0010	0.0010	0.015	1	10/15/2025 14:49	ML	10/20/2025 20:00	MMO	

Quality Control Results

QC Batch: MET/11354 **Analysis Method:** E200.8, ICP-MS Lead/Copper
Preparation Method: E200.8, ICP-MS Lead/Copper
Associated Lab IDs: Q2540322001, Q2540322002, Q2540322003, Q2540322004, Q2540322005, Q2540322006, Q2540322007, Q2540322008, Q2540322009, Q2540322010

Method Reporting Limit Check (2319325)

Parameter	Units	Spiked Amount	Spike Result	Spike Recovery%	Control Limits %	Qualifier
Copper Total	mg/L	0.001	0.0013	129.0	50 - 150	
Lead Total	mg/L	0.001	0.001	104.0	50 - 150	



PWS_1990012_AC_20251006_LCR Analysis Report
LCRA Environmental Laboratory Services
3505 Montopolis Drive
Austin, TX 78744
Phone (512)730-6022
Fax (512)730-6021

1006_LCR Analysis Report
Environmental Laboratory Services
3505 Montopolis Drive
Austin, TX 78744
Phone (512)730-6022
Fax (512)730-6021

Quality Control Results

Quality Control Results

QC Batch: MET/11354

Analysis Method: E200.8, ICP-MS Lead/Copper

Preparation Method: E200.8, ICP-MS Prep

Associated Lab IDs: Q2540322001, Q2540322002, Q2540322003, Q2540322004, Q2540322005, Q2540322006, Q2540322007, Q2540322008, Q2540322009, Q2540322010

Laboratory Fortified Blank (2317558); Lab Fortified Blank Duplicate (2317559)

Parameter	Units	Spiked Amount	Spike Result	%Spike Recovery	Control Limits %	Duplicate Result	%Duplicate Recovery	RPD	RPD Limit	Qualifier
Copper Total	mg/L	0.05	0.0503	101.0	85 - 115	0.0493	98.5	2.01	20	
Lead Total	mg/L	0.05	0.0494	98.7	85 - 115	0.0482	96.5	2.46	20	

Laboratory Reagent Blank(2317557)

Parameter	Units	Results	MRL	LOD	Qualifier
Copper Total	mg/L	<0.00100	0.001	0.001	
Lead Total	mg/L	<0.0010	0.001	0.001	

Laboratory Fortified Matrix (2317560); Lab Fortified Matrix Duplicate (2317561); Original: Q2540322001

Parameter	Units	Spiked Amount	Spike Result	%Spike Recovery	Control Limits %	Duplicate Result	%Duplicate Recovery	RPD	RPD Limit	Qualifier
Copper Total	mg/L	0.05	0.35	81.3	70 - 130	0.352	83.8	0.57	20	
Lead Total	mg/L	0.05	0.0503	100.0	70 - 130	0.0505	101.0	0.397	20	

Copper

Control Limits %
50 - 150